

HIGH POWER LABORATORY

TEST REPORT



Central Power Research Institute

(A Govt. Of India Society,)
P.B.No. 8066, Sadashivanagar S.P.O,
Prof. Sir. C.V. Raman Road,
Bangalore 560 080

TEST REPORT



CPRI

Test Report Number

: HPL14201

Date: 15th December, 2014

Name & Address of the Customer

: M/s. ALP Technologies,
No. 14 & 15, 14th cross,
Bhyraveswara Industrial Estate,
Andrahalli Main Road,
Peenya 2nd stage, Bengaluru - 560 091.

Name & Address of the Manufacturer:

M/s. ALP Technologies,
No. 14 & 15, 14th cross,
Bhyraveswara Industrial Estate,
Andrahalli Main Road,
Peenya 2nd stage, Bengaluru - 560 091.

Particulars of sample tested

Type : 690 V, 2000 A, 80 kA, MCC Panel
Designation : Indoor
Serial number : LT Panel
Number of samples tested : ALP148090
Date(s) of Test(s) : One
CPRI Sample Code No. : 21th October, 2014
Condition of sample on receipt : HPL14S0294
: New

Particulars of tests conducted

: Verification of the short-circuit withstand strength

Test in accordance with
Standard/Specification

: Sub-clause 8.2.3 of IS 8623 (Part 1): 1993/ IEC Pub 439-1 (1985)
(Reaffirmed 2004)

Sampling Plan

: Nil

Customer's requirement

: Nil

Deviation if any

: Nil

Remarks if any

: Nil

Name of the witnessing persons

Customer's representative

: Mr. Subramanya. S.K, CEO

Other than Customer's representative

: None

Test subcontracted with address of
the laboratory

: Nil

Documents constituting this report (In words)

Number of sheets : Six
Number of oscillograms : One
Number of graphs : Nil
Number of photos : Three
Number of test circuit diagrams : One
Number of sample drawings : Two

(R. Manohara)
TEST ENGINEER



(J. Santhosh)
JOINT DIRECTOR

Test Report No. HPL14201

DESCRIPTION OF SAMPLE TESTED

(As assigned by the manufacturer)

Sample	: MCC Panel
Type	: Indoor
Designation	: LT Panel
Serial number	: ALP148090
Rated voltage	: 690 V
Rated normal current	: 2000 A
Frequency	: 50 Hz
Number of phases	: Three
Rated Insulation level	: 690 V rms
Rated short- time withstand current & peak withstand current	: 80 kA rms & 176 kA peak for Main busbars
Duration of short circuit	: 1.0 second



(R. Manohara)
TEST ENGINEER

Test Report No. HPL14201

LIST OF DRAWINGS AND PHOTOGRAPHS**Drawings of the sample tested**

The manufacturer has guaranteed that the sample submitted for the test has been manufactured in accordance with the following drawings. It is verified that these drawings adequately represent the sample tested.

Sample drawing numbers

Sl.No	Drawing No.	Page No.	REV
1	ALP14-9001_SC	1	00
2	ALP14-9001_CPRI_SC	2	00

Total drawings (Duly attested) : Two

Photographs of the sample tested:

Mounting arrangement before test : 334

Condition of the sample after test : 335(Two)

Total photographs : Three

Accuracy of Measurement : The measurement uncertainty for current measurements in this report is by taking into the account of total measuring system;

$$I_1 = \pm 1.856$$

$$I_2 = \pm 1.856$$

$$I_3 = \pm 1.856$$



(R. Manohara)
TEST ENGINEER

Test Report No. HPL14201

SCHEDULE OF TESTS

VERIFICATION OF THE SHORT-CIRCUIT WITHSTAND STRENGTH

Source : Short circuit generator & high current transformer
Number of phases : Three
Frequency : 50 Hz
Neutral : Isolated

Sample
Number of phases : Three (Test on Main Bus-bars)
Condition of sample before test : New
Enclosure : Isolated and grounded through fine wire fuse in series with resistance.
Short circuit point : Grounded

Test on Main Bus-bars
Test circuit drawing number : CRTL/HPL/3SC34

Oscillogram Number	Peak Current (kA)	RMS Current (kA)				Duration (secs)	Observations
		I1	I2	I3	Iavg		
HPL14201S003	180	73.5	77.0	71.5	74.0*	1.17	During test: No abnormalities.
*Equivalent to 80.04 kA rms for 1.0 second							

Condition of the sample after test : No visible damages or deformation of Bus-bars.
 All support insulators found intact.
 Fine wire fuse intact.



(R. Manohara)
TEST ENGINEER

Test Report No. HPL14201

CPRI

VERIFICATION OF THE DIELECTRIC PROPERTIES

Condition of the sample: As after verification of the short circuit withstand strength.

Test procedure	Observation
A high voltage power frequency of 3.5 kV rms for one minute was applied between;	
a) All the phases connected together & enclosure connected to earth.	Withstood
b) Each phase & all other phases & enclosure connected to earth.	Withstood

Physical Inspection

Condition of bus-bars : No visible damage or deformation
Condition of support insulators : Intact

Remarks: The performance of sample tested complies with the requirements of the Sub-clause 8.2.3 of IS 8623 (part 1):1993/ IEC Pub 439-1 (1985) (Reaffirmed 2004) for the tests conducted.



(R. Manohara)
TEST ENGINEER




Test Report No. HPL14201

NOTE

- a) The Test results relate only to the item(s) tested.
- b) Publication or reproduction of the test report/Certificate in any form other than by complete set of the whole test report/Certificate and in the language written is not permitted without the written consent of CPRI.
- c) Any Corrections/erasure invalidates the test Report/Certificate
- d) NABL has accredited this laboratory as per ISO 17025-2005 standard, vide certificate no. T-0010 for the tests carried out.
- e) Any anomaly/discrepancy in the test report/Certificate should be brought to the notice of CPRI within 45 days from the date of issue.

(R. Manohara)
TEST ENGINEER



High Power Laboratory
CPRI, Bangalore

[Signature]
Test Engineer

HPL14201S003
21-October-2014



Photograph No. 334: Mounting arrangement before test

A handwritten signature in blue ink, which appears to read 'R. Manohara'.

(R. Manohara)
TEST ENGINEER

Test Report No. HPL14201



Photograph No. 335: Condition of the sample after test

A handwritten signature in blue ink, likely belonging to the Test Engineer, R. Manohara.


(R. Manohara)
TEST ENGINEER


HIGH POWER LABORATORY
P. B.NO. 8066, SADASHIVANAGAR SUB P.O
PROF. SIR.C.V. RAMAN ROAD, BANGALORE-560 080, INDIA
PHONE: + 91- (0) 80-23600574, FAX: + 91 (0) 80-23601213



Photograph No. 335: Condition of the sample after test

(R. Manohara)
TEST ENGINEER





DATE	12.10.2014
APPROVED BY	S.S.
CHECKED BY	A.J.
DRAWN BY	A.J.

MANUFACTURER
M/s. ALP Technologies
No. 14 & 15, 14th Cross, Bhyraveswara Industrial Estate,
Andrahalli Main Road, Peenya 2nd Stage
Bangalore-560 091, Land Line - 080 - 28567788

SC TEST - CONTROL PANEL - 80KA FOR 1 SEC
Customer

Page Description
INSULATOR DETAILS

Rev	Description	Date
00	INITIAL DRAWINGS	22.10.2014

VENDOR DOC NO:
ALP14-9001_CPRL_SC